LISTING SERVICE

LISTING No.   7120-0067:055   Page 1 of 1

CATEGORY: Annunciators

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Models RL-3, RL-4, RL-6, RL-30, RL-40, RLC-11, RLI-1, RLI-2, RLP-4, RLP-8, RLP-12, RLW-11, RSAC-11 and RSAW-11 remote annunciator lamps; Model RT38 remote trouble indicator; Model RA38 remote alarm; and Model RTA38 remote trouble/alarm indicator. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as annunciators and indicators for use with separately listed compatible fire alarm control units except Models RT38, RA38 and RTA38 are intended for use only with System 3 control unit (CSFM Listing No. 7165-0067:035). Lamps for use with listee's separately listed compatible ionization smoke detectors that are concealed or otherwise not exposed to view.

*Rev.10-26-2002

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2004**   *Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager